



Report for:

**David Brossman, Shruti Sharma**  
**SJV Enterprises, LLC dba Servpro of Western Lancaster**  
30 W. Sunhill Road  
Manheim, PA 17545

---

Regarding: Project: Borough; Demolition  
EML ID: 1964321

Approved by:

Approved Signatory  
Balu Krishnan

Dates of Analysis:  
Asbestos PLM: 07-23-2018

Service SOPs: Asbestos PLM (EPA 40CFR App E to Sub E of Part 763 & EPA METHOD 600/R-93-116, SOP EM-AS-S-1267)

---

All samples were received in acceptable condition unless noted in the Report Comments portion in the body of the report. The results relate only to the items tested. The results include an inherent uncertainty of measurement associated with estimating percentages by polarized light microscopy. Measurement uncertainty data for sample results with >1% asbestos concentration can be provided when requested.

EMLab P&K ("the Company") shall have no liability to the client or the client's customer with respect to decisions or recommendations made, actions taken or courses of conduct implemented by either the client or the client's customer as a result of or based upon the Test Results. In no event shall the Company be liable to the client with respect to the Test Results except for the Company's own willful misconduct or gross negligence nor shall the Company be liable for incidental or consequential damages or lost profits or revenues to the fullest extent such liability may be disclaimed by law, even if the Company has been advised of the possibility of such damages, lost profits or lost revenues. In no event shall the Company's liability with respect to the Test Results exceed the amount paid to the Company by the client therefor.

---



**EMLab P&K**

3000 Lincoln Drive East, Suite A, Marlton, NJ 08053  
 (866) 871-1984 Fax (856) 334-1040 www.emlab.com

Client: SJV Enterprises, LLC dba Servpro of Western Lancaster Date of Sampling: 07-17-2018  
 C/O: David Brossman, Shruti Sharma Date of Receipt: 07-19-2018  
 Re: Borough; Demolition Date of Report: 07-23-2018

**ASBESTOS PLM REPORT**

**Total Samples Submitted: 3**  
**Total Samples Analyzed: 3**  
**Total Samples with Layer Asbestos Content > 1%: 3**

**Location: 1st Floor, Main Flooring Sample**

Lab ID-Version‡: 9254457-1

Sample Layers	Asbestos Content
Multicolored Sheet Flooring with Fibrous Backing	Detected
Yellow Mastic	Not detected
<b>Composite Non-Asbestos Content:</b>	25% Cellulose 5% Glass Fibers
<b>Sample Composite Homogeneity</b>	Good

**Location: 2nd Floor, Bathroom Vinyl Sample**

Sample Layers	Asbestos Content
Pink Sheet Flooring	Not detected
<b>Composite Non-Asbestos Content</b>	5% Glass Fibers
<b>Sample Composite Homogeneity:</b>	Good

**Location: 3rd Floor, Main Flooring Sample**

Sample Layers	Asbestos Content
Black Sheet Flooring /Black Tar Felt	<b>Detected</b>
<b>Composite Non-Asbestos Content</b>	40% Cellulose
<b>Sample Composite Homogeneity:</b>	Good

The test report shall not be reproduced except in full, without written approval of the laboratory. The report must not be used by the client to claim product certification, approval, or endorsement by any agency of the federal government. EMLab P&K reserves the right to dispose of all samples after a period of thirty (30) days, according to all state and federal guidelines, unless otherwise specified. Inhomogeneous samples are separated into homogeneous subsamples and analyzed individually. ND means no fibers were detected. When detected, the minimum detection and reporting limit is less than 1% unless point counting is performed. Floor tile samples may contain large amounts of interference material and it is recommended that the sample be analyzed by gravimetric point count analysis to lower the detection limit and to aid in asbestos identification.

‡ A "Version" indicated by -"x" after the Lab ID# with a value greater than 1 indicates a sample with amended data. The revision number is reflected by the value of "x".